



**LEGEND:**

- O.D.= OUTSIDE DIAMETER
- H= BACKFILL COVER ABOVE TOP OF PIPE
- d= INSIDE DIAMETER
- h=  $\frac{O.D.}{8}$  4" MINIMUM

**NOTES:**

1. MINIMUM COVER - STORMWATER 3', SANITARY 4', WATER 5'.
2. FOR ROCK OR OTHER NON-COMPRESSIVE MATERIALS; THE TRENCH SHOULD BE OVER-EXCAVATED A MINIMUM OF 6" AND REFILLED WITH GRANULAR MATERIAL.