



NOTES:

1. ALL SANITARY SEWER MAINS AND BUILDING SERVICE LINES CONSTRUCTED WITHIN 50 FEET OF AN EXISTING WELL SHALL BE CONSTRUCTED USING PVC (SDR 21) PIPE OR A MATERIAL APPROVED BY THE WATER RESOURCES DEPARTMENT.