



NOTES:

1. ALL CONCRETE TO BE A MINIMUM OF 4500 PSI @ 28 DAYS.
2. MANUFACTURED IN ACCORDANCE WITH ASTM C-478 AND INDOT SPEC. 907.04.
3. MANHOLE JOINTS TO BE TONGUE AND GROOVE WITH BUTYL RUBBER SEALANT OR O'RING PER ASTM C-443.
4. LIFTING HOLES REQUIRE PLUGGING BEFORE TESTING.
5. PIPE CONNECTIONS AVAILABLE ARE PSX BOOTS, A-LOK OR NON-SHRINK GROUT BY CONTRACTOR.
6. PRE-POURED INVERTS ARE AVAILABLE ON REQUEST.
7. ALL REINFORCING STEEL MEETS OR EXCEEDS ASTM C-478.
8. BASE SECTION COMES STANDARD WITH 6" MONOLITHIC BASE. SEPARATE BASE AND FLAT TOP IS AVAILABLE ON REQUEST. BASE SECTION IS TO BE SET PER JOB SPECIFICATIONS.
9. CONTRACTOR SHALL POUR SLOPED CONCRETE BOTTOM TO ALLOW ADEQUATE DRAINAGE IN INLET.
10. THE CASTING TO BE USED WITH THIS INLET SHALL BE A 2'X2' CURB AND GUTTER OR A 2'X2' ALLEY OR OTHER PRE-APPROVED CASTING AS NOTED ON THE PROJECT DETAIL SHEET(S).
11. WEIGHTS FOR THE 1' HEIGHT IS 384 LBS, THE BASE IS 560 LBS, AND 4' HEIGHT IS 1950 LBS.
12. THE REINFORCING STEEL IS 0.12 SQ. IN. / L.F. (MINIMUM)